

GVYI.R10470 - Gasketing and Edge-sealing Materials for Fire Doors, Positive-pressure Tested

Gasketing and Edge-sealing Materials for Fire Doors, Positive-pressure Tested

[See General Information for Gasketing and Edge-sealing Materials for Fire Doors, Positive-pressure Tested](#)

REESE ENTERPRISES INC

R10470

16350 ASHER AVE E

PO BOX 459

ROSEMOUNT, MN 55068-0459 USA

Self-Adhesive Perimeter Seal Model* 797 Category H Smoke and Draft Control Gasket for use with wood core doors rated 20 minutes fire tested without hose stream. The Model 797 may be used with the Model 183 astragal when the 797 is installed on the meeting edge of a door pair.

Self-Adhesive Perimeter Seal Models* 637, 638, 793, 797, 798 Category H Smoke and Draft Control Gasket for use with steel covered composite and hollow-metal doors rated up to 3 hrs fire tested with hose stream, wood and plastic covered composite fire doors rated up to 1-1/2 hr fire tested with hose stream, and wood core doors rated up to 20 minutes with hose stream. The Models 637, 638, 797 and 798 may be used with the 183 astragal when installed on the meeting edge of a door pair. The Model 793 shall be used with the Model 792 astragal when installed on a door pair.

Jamb Up Type Perimeter Seal Models* 33, 39, 49, 59, 93, 95, 99, 128, 373, 399, 599, 612, 616, 619, 633, 653, 654, 655, 657, 659, 669, 678, 688, 755, 757, 769, 770, 771, 774, 775, 778, 779, 788, 795, 807, 809, 815, 818, 855, 875, DS69, DS70, DS76, DS77, DS78, DS79, 364SS Category H Smoke and Draft Control Gaskets for use with hollow-metal doors rated up to 3 hrs fire tested with hose stream, , wood and plastic covered composite fire doors rated up to 1-1/2 hr fire tested with hose stream, and wood core doors rated up to 20 minutes with hose stream.

Nylon Brush Type Perimeter Seal Models* 918, 934, 956, 957, 958, 959, 961, 964, 967 Category H Smoke and Draft Control Gasket for use with steel covered composite and hollow-metal doors rated up to 3 hrs fire tested with hose stream, wood and plastic covered composite fire doors rated up to 1-1/2 hr fire tested with hose stream, and wood core doors rated up to 20 minutes with hose stream.

Astragal Type Seal Models* M35, 92, 93, 103, 203, 959, 964, 967 Category H Smoke and Draft Control Gasket for use with steel covered composite and hollow-metal doors rated up to 1-1/2 hrs fire tested with hose stream, wood and plastic covered composite fire doors rated up to 1-1/2 hr fire tested with hose stream, and wood core doors rated up to 20 minutes with hose stream.

Astragal Type Seal Model 792 Category H Smoke and Draft Control Gasket for use with steel covered composite and hollow-metal doors rated up to 3 hrs fire tested with hose stream, wood and plastic covered composite fire doors rated up to 1-1/2 hr fire tested with hose stream, and wood core doors rated up to 20 minutes with hose stream. The Model 792 shall be used with the Model 793 perimeter seal when installed on a door pair.

Gasketing materials, Series, Models* 33, 39, 49, 59, 92/103S, 93, 95, 99, 128, 129, 192, 364, 373, 399, 402, 403, 499, 599, 608, 612, 616, 619, 629, 630, 631, 632, 633, 637, 638, 653, 655, 657, 659, 669, 678, 688, 754, 755, 757, 758, 759, 769, 770, 771, 775, 778, 779, 786, 788, 792, 793, 794, 795, 797, 798, 807, 809, 815, 817, 818, 819, 821, 822, 854, 855, 856, 858, 859, 863, 866, 875, 884, 888, 889, 897, 918, 934, 954, 955, 956, 957, 958, 959, 961, 962, 964, 965, 967, 968, 970, 973, 976, 4618, DS54, DS62, DS63, DS69, DS-70, DS-75, DS-76, DS-77, DS-78, DS-79, DS-106, F-654, F-774, 129BR, 129PR, Category J Gaskets for use with Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 3 hrs; wood and plastic covered composite doors rated up to 1-1/2 hrs; and wood core doors rated for 20 minutes.

Automatic Door Bottom, Models F-320, F-321, F-330, F-370, F-371, F-372, F-430, F-521, F-933, F-943. Category J Gaskets for use with Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 3 hrs; wood and plastic covered composite doors rated up to 1-1/2 hrs; and wood core doors rated for 20 minutes

Astragal Models 92/103S, 93, 95, 95P, 95V, 103, 129, 183, 203, 276, 393, 678, 688, 792, 804, 807, 959, 961, 964, 967, DS75, M35, 129BR. Category J Gaskets for use with Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 3 hrs; wood and plastic covered composite doors rated up to 1-1/2 hrs; and wood core doors rated for 20 minutes.

Door Sweep, Models* F-64, F-214, F-323, F-353, F-354, F-362, F-377, F-414, F-602, F-603, F-701, F-702, F-703, F-704, F-712, F-772, F-773, F-805, F-806, F-810, F-825, F-959, F-960, F-962, F-963, F-964, F-965, F-966, F-967, F-968, F-969, F-970, F-971, F-973, F-977, F-978, F-979, F-980, F-981, F-982, F-983, F-984, F-985, F-DB469, F-DB591, F-DB592, F-DB593, F-DB594, F-DB595, F-DB596, F-DS610, F-DS611, F-DS180, F-M15, F-M35, 1030, 1031, 1032, 1033, 129BR Category J Gaskets for use with Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 3 hrs; wood and plastic covered composite doors rated up to 1-1/2 hrs; and wood core doors rated for 20 minutes.

Threshold Models, Gasketing materials, Series 568, 657, 720, 721, 854, 855, 875, DS180, S181, S248, S252, S257, S281, S282, S283, S284, S285, S297, S470, S473, S475, S482, S483, S484, S485, S486, S487, S488, S489, S490, S498, S500, S501, S502, S514, S567, S598, S714, TS-1, TS-2, V138, V299, V300, V301, thresholds intended for application to Listed steel frames and/or Classified hollow metal and steel composite type fire doors rated up to and including 3 hours, wood composite fire doors up to 1-1/2 hrs and wood core type rated twenty minutes without hose stream.

Self-Adhesive Perimeter Seal Model* 587 Category G edge seal for use with wood and plastic covered composite fire doors rated up to 1-1/2 hr fire tested with hose stream, and wood core doors rated up to 20 minutes with hose stream. Category J edge seal when used for these applications steel covered composite and hollow-metal doors rated up to 3 hrs fire tested with hose stream. The model 587 may be used with any category H or J seal on this page when installed in accordance with manufacturer's installation instructions.

Combination edge sealing and smoke seal system, Model No. 588 Category G / Category H Edge Seal / Smoke Seal and Draft Control Gasket for use with Classified Category B wood and plastic covered composite and wood core doors rated up to 1-1/2 hr., and Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to and including 3 hrs., up to 4 ft. x 9 ft. single swing and 8 ft. x 9 ft. standard pair. Also suitable as a Category J gasket.

Gasketing Materials for fire doors, Threshold Models 1010, 1011, 1012, 1013, 1020, 1021. These Category J thresholds are intended for use UL Listed steel frames and/or Classified steel-covered composite, hollow-metal doors rated up to 3 h; wood and plastic-covered composite doors rated up to 1-1/2 h; and wood core doors rated 20 min.

* May include additional prefix or suffix letters.

Last Updated on 2020-07-16

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2021 UL LLC"