

GSZN.R39309 - SWINGING-TYPE FIRE DOORS, POSITIVE-PRESSURE TESTED

Swinging-type Fire Doors, Positive-pressure Tested

See General Information for Swinging-type Fire Doors, Positive-pressure Tested

FORTIS DOORS SAS
Calle 76 #55-30
055410 Itagui, COLOMBIA
Swinging doors may be provided as follows:

R39309

Max.		Door	Opening	Min Size ft- in(mm)	Max Size ft-in(mm)		Temp Rise Rating		Smoke			
Model	Rating	Type	Type		Category	W	H	W		H	Latching Hardware	Accessories [*]
-	3 hour	Hollow-Metal (Honeycomb)	Single	A	-	-	3 - 6.69 (1084)	7 - 9.37 (2372)	Cylindrical, Mortise, Mortise Fire Exit, Rim Exit, Tubular	Auxiliary Locks, Cladding, Concealed Closer, Fire Door Viewer, Glazing, Louver	-	-
-	1-1/2 hour	Hollow-Metal (Honeycomb)	Single	A	-	-	3 - 6.69 (1084)	7 - 9.37 (2372)	Cylindrical, Mortise, Mortise Fire Exit, Rim Exit, Tubular	Auxiliary Locks, Cladding, Concealed Closer, Fire Door Viewer, Glazing, Louver	-	-

[*] - Additional information regarding accessories can be found under the Guide Card GSZN

Last Updated on 2018-02-05

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"